



SITE INSPECTION RECORD

CLIENT / CONTRACTOR:

PROJECT/SITE:

Miller Rd - Chester Hill

JOB No.

YN 2/0015

CONTRACT No.

NA

DATE:

11/12/2013

TIME:

2:30 pm

WEATHER:

Sunny - warm

REPORT / INSTRUCTION:

RW Near Windi Ave.

• Pier layout generally in accordance with the construction plans

• Bl concrete slab near SW pit identified

• Approx. 2 Holes not Augered

• Ensure holes free of any loose material prior to placement of cage & concrete

• Ensure covers to steel maintained as per the drawings

STRUCTURAL INSPECTION

Footing

Slab

Frame

Approved

Approved

(Subject to Completion of Items noted)

Not Approved

Signed

G. P. [Signature]

for

[Redacted]

[Signature]

Vince [Signature]